



# CITY OF MARSHALL


## DEPARTMENT OF BUILDING SAFETY


### Glazing Hazardous Locations Residential Uses

#### R 308.4—Hazardous Locations

1. Glazing in side-hinged door except jalousies
2. Glazing in fixed and sliding panels in sliding and bi-fold closet door assemblies and panels in sliding and bi-fold closet door assemblies
3. Glazing in storm doors
4. Glazing in doors and enclosures for hot tubs, whirlpools, saunas, steam rooms, bathtubs and showers. Glazing in any part of a building wall enclosing these compartments where the bottom exposed edge of the glazing is less than 60 inches measured vertically above any standing or walking surface.
5. Glazing, in an individual fixed or operable panel adjacent to a door where the nearest vertical edge of the glazing is within a 24 inch arc of the door in a closed position and whose bottom edge is less than 60 inches above the floor or walking surface.
6. Glazing in an individual fixed or operable panel, other than those locations described in Items 5 and 6 above, shall meet all the following conditions;
  - 6.1 Exposed area of an individual pane greater than 9 square feet
  - 6.2 Bottom edge less than 18 above the door
  - 6.3 Top edge greater than 36 inches above the floor
  - 6.4 One or more walking surfaces with 36 inches horizontally of the glazing.
7. All glazing in railings regardless of an area or height above a walking surface. Included are structural baluster panels and nonstructural in-fill panels.
8. Glazing in walls and fences enclosing indoor and outdoor swimming pools, hot tubs and spas, where the bottom edge of the pool or spa side is less than 60 inches above a walking surface and within 60 inches horizontally of the water's edge. This shall apply to single glazing and all panes in multiple glazing.
9. Glazing in walls enclosing a stairway landings or within 60 inches of the top and bottom of stairways where the bottom edge of the glass is less than 60 inches above the walking surface.

See the diagram on the next page on Safety Glazing in Close Door  
Proximity to Windows.







City of Marshall  
Department of Building Safety  
323 W. Michigan Ave.  
Marshall, Michigan 49068